

January 30, 2025

**M. Jean-François Durocher**

*Water Inspector – Provincial Officer*

Ministry of the Environment, Conservation and Parks

**Subject:**

**2024 - Performance Report for the Fournier Wastewater Facility**

---

M. Durocher,

The following document includes the 2024 Performance Report for the Fournier Wastewater Facility, covering the period from January 1<sup>st</sup> to December 31<sup>st</sup>, 2024, inclusive.

In this Performance Report a summary of the Fournier Wastewater Facility will be discussed.

- Volumes and daily flow rates of wastewater
- Results of raw sewage and final effluent parameters
- Summary of operation and environmental challenges
- Maintenance and calibration of monitoring equipment.

This document follows condition 7 of the Certificate of Approval No. 1128-5S6KLC approved on December 23<sup>rd</sup>, 2003.


Sincerely,



(Prepared by)

Sebastien Cadieux,

Senior Water & Wastewater Operator/Compliance Officer



(Reviewed & Approved)

Nicholas Pigeon,

Director of Water & Wastewater

## **2024 Annual Performance Report for the Fournier Wastewater Facility**

**a) A summary and interpretation of all raw sewage and effluent monitoring data and a comparison to effluent objectives outlined in Condition 5, including an overview of the success and adequacy of the works.**

The volumes of the final effluent are estimated using the run times and theoretical pump rates. The average daily flow (ADF) of wastewater entering the Fournier Wastewater Facility was 67.9 m<sup>3</sup>/Day from January to December 2024.

The average treated effluent daily flow was 95.1 m<sup>3</sup>/day.

The Fournier Wastewater Treatment Facility did not encounter any major challenges during 2024 and satisfied the effluent limits for Carbonaceous BOD<sub>5</sub> and Total Suspended Solids.

Raw sewage analyses were performed quarterly for the Fournier Wastewater Facility.

### 1) Total Nitrogen (Kjeldahl) and ammonia

The treated final Effluent concentration of Ammonia averaged 5.91 mg/L in 2024.

### 2) Total Phosphorus

The treated final effluent concentration of Total Phosphorus averaged 3.70 mg/L in 2024. There is no effluent limit for total phosphorus at the Fournier Wastewater Treatment Facility.

### 3) Carbonaceous Biological Oxygen Demand (CBOD5)

The treated final effluent concentration of CBOD5 average 1.67 mg/L in 2024, which is below the effluent objective limit of 10 mg/L.

### 4) Suspended Solids

The average treated final effluent concentration for Total Suspended Solids was 9.42 mg/l in 2024, which is below the effluent objective limit of 10 mg/L.

### 5) E. Coli

The average treated final effluent concentration for E. Coli was 43767 CFU/100mL in 2024.

**b) A summary and interpretation of all groundwater monitoring data and comparison to the established baseline background groundwater quality.**

Groundwater monitoring is done according to Section 4.3 Tables 3 to 6 of Certificate of Approval No. 1128-5S6KLC. The Nation municipality, Environmental department is in charge for the sampling of the groundwater monitoring wells and the Engineering Firm EXP is following the program with a report that is submitted to the MECP.

**c) A delineation of the septic effluent impacted groundwater plume and the documentation of the movement and anticipated arrival of the plume at monitoring wells MW99-4 and MW99-5**

Groundwater monitoring is done according to Section 4.3 Tables 3 to 6 of Certificate of Approval No. 1128-5S6KLC. See EXP Engineering report.

**d) A tabulation of the daily volumes of effluent disposed through the subsurface system during the reporting period.**

The volumes of the final Effluent are estimated using the run times and theoretical pump rates of the Effluent pumps. See the Fournier Wastewater Facility – Analytical Survey 2024, Table at the end of this report.

**e) A summary of all maintenance carried out on any major structure, equipment, apparatus, mechanism or thing forming part of the works.**

In addition to regular preventative maintenance, the following operational duties were performed.

- **May**
  - Clean and flush Sanitary Collection system with Nation's Personnel and hydrovac
  - Cleaning of SPS #1 and # 2 with the Nation's Personnel and hydrovac.
- **June,**
  - Annual Maintenance at Fournier Field
  - Removed 44 000 gallons of sludge with the Nation hydrovac
- **November,**
  - Cleaning of SPS #1 and # 2 with the Nation's Personnel and hydrovac.

**f) A description of any operating challenges encountered, and corrective actions taken.**

There were no operating challenges encountered during the 2024 period.

**Appendix I: FOURNIER WASTEWATER FACILITY - ANALYTICAL SURVEY – 2024.**

# APPENDIX I

### Waste Water - Analytical survey



Fournier

2024		Limit Objectives	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	total
<b>RAW SEWAGE</b>															
Total Flow	$m^3$		2172	1907	1354	2533.3	2264.5	2127.6	2544.7	2743.7	1857.5	1711.3	1694.2	1950.0	24859.8
Daily Ave. Flow	$m^3/d$	97.6	70.1	65.8	43.7	84.4	73.0	70.9	82.1	88.5	61.9	55.2	56.5	62.9	67.9
Max Flow	$m^3/d$		89.4	79.8	104.5	94.4	83.4	84.5	93.1	110.0	81.6	61.6	58.7	73.3	110.0
Min. Flow	$m^3/d$		66.5	59.8	67.1	67.1	57.4	65.8	60.7	60.7	51.4	50.4	55.4	52.9	50.4
CBOD <sub>5</sub>	mg/l			140			46			77			191		114
TSS	mg/l			108			104			165			1480		464
TKN	mg/l			90.9			36.2			54.7			264		111
Ptot	mg/l			8.99			4.11			6.71			16.3		9.0
<b>EFFLUENT</b>															
Total Flow	$m^3$		635.7	2857.9	3621.4	2946.8	3920.4	3458.1	3638.8	3593.0	2476.9	1810.9	2441.4	3281.3	34682.8
Daily Ave. Flow	$m^3/d$		20.5	102.1	116.8	98.2	126.5	115.3	117.4	115.9	82.6	58.4	81.4	105.8	95.1
CBOD <sub>5</sub>	mg/L	10.0	5	0	5	4	3	0	0	0	0	0	3	0	1.67
TSS	mg/L	10.0	7	4	18	6	7	0	11	6	0	30	11	13	9.42
Alkalinity	mg/L		236	304	309	286	309	261	234	258	231	211	189	188	251.33
Nitrite	mg/L		0.07	0.1	0.84	0.4	0.4	0	0.08	0	0.17	0	0	0	0.17
Nitrate	mg/L		17.2	3.24	3.85	7.44	4.58	14.6	15.9	19.9	18.4	23	29.2	31.4	15.73
Total Ammonia	mg/L		7.34	10.2	16	12.3	11.1	1.41	1	0.63	1.67	1.22	5.75	2.3	5.91
TKN	mg/L		8.9	12.3	20.5	17.1	13.1	2.6	2.3	1.9	2.8	2.4	8.9	4	8.07
Total Phosphorus	mg/L		3.33	3.68	4.05	3.55	3.34	2.62	2.38	2.91	3.77	4.95	5.26	4.61	3.70
E Coli.	cfu/100mL		80000	62000	88000	59000	145000	10000	7000	7000	300	2100	64000	800	43767

